



Division of Environmental Health Office of Drinking Water

Help

View Sample Detail - WSID 532750 - MEADOWMEER

Collect Date 12/19/2019
 Lab Number 193
 Lab Name Dragon Analytical Laboratory
 Sample Number 49685
 Source 05
 Analyte Group IOC-INORGANIC CONTAMINANTS
 Test Panel IOC-COMPLETE INORGANIC ANALYSIS
 Sample Location well 5
 Sample Type Unknown

Result Range, A/P, Units: Mouse over for full description

Analyte DOH Num	Analyte Name	Result Range	Result Quantity	Maximum Contaminant Level	State Reporting Limit	Units
0008	IRON	EQ	11.8000	0.3000	0.1000	mg/L
0018	COLOR	EQ	120.0000	15.0000	15.0000	CU
0004	ARSENIC	EQ	0.0011	0.0104	0.0010	mg/L
0010	MANGANESE	EQ	0.0330	0.0500	0.0100	mg/L
0014	SODIUM	EQ	5.5000		5.0000	mg/L
0015	HARDNESS	EQ	75.2000		10.0000	mg/L
0016	CONDUCTIVITY	EQ	211.0000	700.0000	70.0000	Umhos/cm
0017	TURBIDITY	EQ	1.9000		0.1000	NTU
0026	TDS-TOTAL DISSOLVED SOLIDS	EQ	129.0000	500.0000	100.0000	mg/L
0005	BARIUM	LT	0.1000	2.0000	0.1000	mg/L
0006	CADMIUM	LT	0.0010	0.0050	0.0010	mg/L
0007	CHROMIUM	LT	0.0070	0.1000	0.0070	mg/L
0009	LEAD	LT	0.0010		0.0010	mg/L
0011	MERCURY	LT	0.0002	0.0020	0.0002	mg/L
0012	SELENIUM	LT	0.0020	0.0500	0.0020	mg/L
0013	SILVER	LT	0.1000	0.1000	0.1000	mg/L
0019	FLUORIDE	LT	0.2000	4.0000	0.2000	mg/L
0020	NITRATE-N	LT	0.0038	10.0000	0.5000	mg/L
0021	CHLORIDE	LT	20.0000	250.0000	20.0000	mg/L
0022	SULFATE	LT	50.0000	250.0000	50.0000	mg/L
0023	COPPER	LT	0.0200		0.0200	mg/L
0024	ZINC	LT	0.2000	5.0000	0.2000	mg/L
0110	BERYLLIUM	LT	0.0003	0.0040	0.0003	mg/L
0111	NICKEL	LT	0.0050	0.1000	0.0050	mg/L
0112	ANTIMONY	LT	0.0030	0.0060	0.0030	mg/L

Records 1 - 25 of 28

[Home Page](#) | [Find Water Systems](#) | [Find Water Quality](#) | [Downloads/Reports](#)

[DOH Home](#) | [Community and Environment](#) | [Drinking Water Home](#) | [Drinking Water Contacts](#)
[Access Local Health](#) | [Privacy Notice](#) | [Disclaimer/Copyright Information](#)

Links to external resources are provided as a public service and do not imply endorsement by the Washington State Department of Health



Division of Environmental Health Office of Drinking Water


Help

View Sample Detail - WSID 532750 - MEADOWMEER

Collect Date 12/19/2019
Lab Number 193
Lab Name Dragon Analytical Laboratory
Sample Number 49685
Source 05
Analyte Group IOC-INORGANIC CONTAMINANTS
Test Panel IOC-COMPLETE INORGANIC ANALYSIS
Sample Location well 5
Sample Type Unknown

Result Range, A/P, Units: Mouse over for full description

Analyte DOH Num	Analyte Name	Result Range	Result Quantity	Maximum Contaminant Level	State Reporting Limit	Units
0113	THALLIUM	LT	0.0010	0.0020	0.0010	mg/L
0114	NITRITE-N	LT	0.1000	1.0000	0.1000	mg/L
0161	TOTAL NITRATE/NITRITE	LT	0.0038		0.5000	mg/L



Records 26 - 28 of 28

[Home Page](#) | [Find Water Systems](#) | [Find Water Quality](#) | [Downloads/Reports](#)

[DOH Home](#) | [Community and Environment](#) | [Drinking Water Home](#) | [Drinking Water Contacts](#)
[Access Local Health](#) | [Privacy Notice](#) | [Disclaimer/Copyright Information](#)

Links to external resources are provided as a public service and do not imply endorsement by the Washington State Department of Health

Department of Health, Office of Drinking Water

Street Address:

243 Israel Road S.E. 2nd floor
Tumwater, WA 98501

Mail:

PO BOX 47822
Olympia, WA 98504-7822

Send inquiries about DOH and its programs to the [Health Consumer Assistance Office](#)
Comments or questions regarding this Web site? Send email to [Environmental Health Application Testing and Support](#) or call 888-457-2467.
For technical issues with this website send email to DOH IT Service Desk or call 360-236-4357.